

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.

No. DWTL-BR/049/2026-27.

Date : 27/01/2026.

It is certified that an inspection team headed by Harpreet Singh  
Lab Chemist, Distt Water Testing Laboratory, Ferozpur (Name of Officers  
with designation) from Water Supply & Sanitation Deptt FZR (Name of  
Department/Office) inspected the SBR DAV Public School,  
Talwandi Bhai, Block:-Ghall Khurd, Distt:-Ferozpur (Name & Address of  
the School) on 27-01-2026 and found that the SBR DAV public  
School (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

i.e. 27/01/2026 to 26/01/2027

The above valid for a period of One year.

Harpreet Singh  
27/01/2026

Signature with Seal :

Lab Chemist/J.E. Incharge  
Distt. Water Testing Laboratory  
W/s & Sanitation Deptt.

Name :

Harpreet Singh  
Ferozpur

Designation :

lab chemist

To

The principal  
SBR DAV public School,  
Talwandi Bhai, Distt:-Ferozpur

(Name & Address of the Institution)

**WATER SUPPLY & SANITATION DISTRICT LEVEL WATER TESTING  
LABORATORY  
ANALYSIS REPORT OF WATER SAMPLES**

**Particulars of Samples**

	Sample No. 1	Sample No. 2	Date of Receipt	Date of Conducting
1 Place/Name of Village	SBR DAV public school, Talwandi Bhai		27/01/26	27/01/26
2 Block/District	Ghadi Khurd / Ferozepur			
3 Source	R.O			
4 Date and time of collection	27-01-2026			
5 Depth	-			
6 Spring Level	-			
7 Name and designation of the Person collecting the sample	Smt. Jaswinder Kaur (Principal)			

**TEST RESULTS**

**PHYSICAL AND CHEMICAL**

1 Turbidity (JTU)	-	
2 Colour (Units on Pt-Co Scale)	-	
3 Taste and odors (Qualitative)	-	
4 PH	6.8	
5 Total Dissolved Solids mg/l	074	
6 Total Alkalinity (as CaCo3) mg/l	32	
7 Hardness (as CaCo3)mg/l		
(a) Total	28	
(b) Calcium	0.6	
(c) Magnesium	-	
(d) Carbonate	-	
(e) Non-Carbonate	-	

P.T.O.